

# Employee Housing Regulations

## Article 6.

### Subarticle 4. Fire Equipment and Hazards

#### **§ 744. Fire Extinguishers and Fire Extinguishing Systems**

Fire extinguishers shall comply with the requirements of the State Fire Marshal contained in Title 19, California Administrative Code.

(a) Mess Hall Kitchens. Approved Class B–C type fire extinguishers providing not less than 20 units of extinguishing capacity shall be maintained in each mess hall kitchen.

(b) Dormitories. Approved Class A type fire extinguishers providing not less than two units of extinguishing capacity shall be maintained for each 5,000 square feet (450 square meters) of floor area or portion thereof of any dormitory building.

(c) Equipment. All fire extinguishing systems and equipment shall be adequately maintained to insure their operability in an emergency.

Note: Authority cited: Sections 17003.5 and 17040, Health and Safety Code. Reference: Section 17040, Health and Safety Code.

#### **§ 746. Fire Hazards**

No article or material the enforcement agency determines may be dangerous or create a fire hazard, shall be maintained in or on the premises of a labor camp.

Note: Authority cited: Sections 17003.5 and 17040, Health and Safety Code. Reference: Section 17040, Health and Safety Code.